



Mecklenburg County Land Development Standards Manual (MCLDSM)

Revised July 1, 2010



Mecklenburg County Land Development Standards Manual

Mecklenburg County (Including ETJ) Land Development

Table of Contents

Specifications & Special Provisions:

<u>STREETS</u>	
Page No.	Title
8	A. General Notes
11	B. Standards of Street Design
13	C. Grading
13	D. Roadway Base
14	E. Roadway Intermediate and Surface Course
14	F. Sidewalks and Driveways
<u>STORM DRAINAGE</u>	
Page No.	Title
15	A. General Notes
16	B. High Density Polyethylene Pipe
17	C. Reinforced Concrete Pipe
17	D. Installation of Reinforced Concrete and CMP
18	E. Standards for Design
<u>PLAN REQUIREMENTS</u>	
Page No.	Title
18	A. General Requirements
19	B. Subdivision Preliminary Plan
19	C. Bond Policy for Subdivision Improvements
21	References

Standard Details:

1000 Series - Miscellaneous Infrastructure Standards

<u>Standard</u>	<u>Description</u>
10.17A	Std. Curb and Gutter
10.17B	Curb and Gutter
10.17C	Concrete Contraction Joint
10.18	18" Vertical Curb
10.19	Curb Transition 2'-6" Curb and Gutter to 2'-0" Valley Gutter
10.20	Curb Transition 2'-6" Curb and Gutter to 1'-6" Curb and Gutter
10.22	Concrete Sidewalks
10.23	Monolithic Concrete Curb and Sidewalk
10.24A	Commercial Type II and Residential Type I Drop Curb Driveway with Sidewalk Abutting Curb (2'-6" Curb and Gutter)
10.24B	Commercial Type II and Residential Type I Drop Curb Driveway with Sidewalk Abutting Curb (6"X18" Vertical Curb)
10.24C	Commercial Type II and Residential Type I Drop Curb Driveway with Sidewalk Abutting Curb
10.25A	Residential Drop Curb Type I Driveway with Planting Strip (2'-6" Curb and Gutter)
10.25B	Commercial Drop Curb Type II Driveway with Planting Strip (2'-6" Curb and Gutter)
10.25C	Residential Drop Curb Type I Driveway with Planting Strip (6"X18" Vertical Curb)
10.25D	Commercial Drop Curb Type II Driveway with Planting Strip (6"X18" Vertical Curb)
10.25E	Type II Modified Driveway Detail with wide Planting Strip and Standard Curb
10.25F	Commercial Type IV Driveway Standard
10.26	Drop Curb Driveway – Monolithic Curb and Sidewalk
10.27A	Residential Driveway (Type I) for Valley Gutter
10.27B	Commercial Type II Driveway For 2'-0" Valley Gutter
10.28	Type III Driveway Entrance
10.29	Catch Basin Frame in Valley Gutter
10.30	Catch Basin Placement at Intersections
10.31A	Accessible Ramp Standard with Planting Strip 2'-6" Curb and Gutter
10.31B	Accessible Ramp Sections with Planting Strip 2'-6" Curb and Gutter
10.32A	Accessible Ramp Standard without Planting Strip 2'-6" Curb and Gutter
10.32B	Accessible Ramp Sections without Planting Strip 2'-6" Curb and Gutter
10.33A	Accessible Ramp Standard 2'-0" Valley Gutter
10.33B	Accessible Ramp Sections 2'-0" Valley Gutter
10.34A	Accessible Ramp Standard Monolithic Curb and Sidewalk
10.34B	Accessible Ramp Sections Monolithic Curb and Sidewalk
10.35A	Standard Placement of Accessible Ramps and General Notes
10.35B	Truncated Domes Plan and Cross-Section
10.36A	Culvert Crossings on Residential and Commercial Streets
10.36B	Culvert Crossings on Residential and Commercial Streets
10.37	Typical Local Residential To Local Limited Residential Street Taper
10.38	<i>-removed -</i>
10.39	<i>-removed –</i>
10.40	Directional Accessible Ramp

1100 Series - Street Section Details

<u>Standard</u>	<u>Description</u>
11.01	Local Residential Street Typical Section
11.02	<i>-removed -</i>
11.03	Divided Residential Street Typical Sections
11.04	Local Limited Residential Street Typical Section
11.05	<i>-removed -</i>
11.06	Residential Collector Street Typical Sections
11.07	<i>-removed -</i>
11.08	Limited Residential Collector Street Typical Section
11.09	Arterial Street Typical Sections
11.10	<i>-removed -</i>
11.11	Commercial Street Typical Section
11.12	Commercial Street Divided Typical Section
11.13	Typical Sections Private Street
11.14	<i>-removed -</i>
11.15	<i>-removed -</i>
11.16	Cul-De-Sac Detail
11.17	Commercial Cul-De-Sac Detail
11.18A	Residential Hammerhead Detail
11.18B	Temporary Turnaround
11.19A	Residential Alley Detail One-Way Operation
11.19B	Residential Alley Detail Double Loaded w/ Two-Way Operation
11.19C	Residential Alley Detail Single Loaded w/ Two-Way Operation
11.20	Residential Alley Hammerheads and Intersections
11.21	<i>-removed -</i>
11.50	Cornelius, Davidson, Huntersville Typical Section Residential Street
11.51	Matthews Typical Section Local Residential Street
11.52	Pineville Typical Section Local Residential Street
11.53	<i>-removed -</i>
11.54	Matthews Typical Section Local Limited Residential Street
11.55	Matthews Typical Section Residential Collector Street
11.56	Cornelius, Davidson, Huntersville Typical Section Cul-De-Sac Detail
11.57	Matthews Residential Cul-De-Sac Detail
11.58	Pineville Residential Cul-De-Sac Detail

2000 Series - Storm Drain Standards

<u>Standard</u>	<u>Description</u>
20.00A,B,C	NCDOT Standards Approved For Use in Mecklenburg County and Towns, incl. ETJ
20.03	Brick Double Catch Basin 15”-36” Pipe
20.17A	Concrete Wingwall with Splash Pad
20.17B	Concrete Wingwall with Splash Pad
20.23	Rip Rap Aprons at Pipe Outfalls other than at SWIM
20.23A	Flared End Section 12” Thru 72” Pipe
20.24	Rip Rap Plunge Pool
20.25	Trench Detail for Storm Drain
20.26	Concrete Paved Ditches
20.27	Rip Rap Ditches
20.28	Subdrain Detail
20.29	Overlapping Storm Drain / Sanitary Sewer Easements
20.30	Minimum Drainage Easement Requirements for Storm Drain Pipes and Open Channels
20.34	Offset Catch Basin
20.35	Grading At Drop Inlet

2100 Series – Stormwater BMP Details

<u>Standard</u>	<u>Description</u>
21.00	Bioretention Plan
21.01	Bioretention Cross-Section
21.02	Bioretention Planting Plan
21.03	<i>-removed -</i>
21.04	Flow Splitter Structure
21.05	Wetpond Plan
21.06	Wetpond Profile
21.07	Wetpond Cross-Sections
21.08	Wetpond Littoral Shelf and Berm Detail
21.09	Wetpond Planting Plan
21.10	Wetland Plan
21.11	Wetland Section
21.12	Wetland Cross-Sections
21.13	Wetland Details
21.14	Wetland Planting Plan
21.15	Enhanced Grass Swale Planting Plan
21.16	Enhanced Grass Swale Details
21.17	Grass Channel
21.18	Grass Channel Planting Plan
21.19	Infiltration Trench
21.20	Observation Well
21.21	Buffer Strip
21.22	Buffer Strip Planting Plan
21.23	Underground Sand Filter
21.24	Surface Sand Filter
21.25	Surface Sand Filter Section
21.26	Level Spreader

3000 Series - Erosion Control Standards

<u>Standard</u>	<u>Description</u>
30.00	Special Erosion Control Requirements & Notes
30.01	Temporary Sediment Trap
30.02A	Skimmer Sediment Basin
30.02B	Skimmer
30.03	Sediment Basin
30.04	Flexible Pipe Slope Drain
30.05	Temporary Silt Ditch
30.06A	Temporary Silt Fence
30.06B	High Hazard Temporary Silt Fence
30.06C	Silt Fence Outlet Option 1
30.06D	Silt Fence Outlet Option 2
30.07	Block and Gravel Inlet Protection
30.08	Stone Inlet Protection
30.09	Hardware Cloth and Gravel Inlet Protection
30.10A	Temporary Rock Check Dam
30.10B	Temporary Rock Check Dam with Matting and Optional PAM
30.10C	Temporary Wattle Check Dam with Matting and Optional PAM
30.11A	Stabilized Construction Entrance
30.11B	Construction Entrance Tire Wash
30.12	Gravel and Rip Rap Filter Berm Basin
30.13	Erosion Control Dewatering
30.14	Temporary Stream Crossing
30.15	Catch Basin Inlet Protection
30.16	Slope Stability
30.17A	Seeding Schedule
30.17B	Seeding Schedule (Seasonal)
30.18	Construction within Creek Bank
30.19	Baffle Installation
30.20	Embankment Matting Detail
30.21	Brick Storm Structure with Temporary Pipe

4000 Series - Tree Standards

<u>Standard</u>	<u>Description</u>
40.01	Tree Planting
40.02	Tree Protection
40.03	Tree Pit with Grate in Sidewalk (Plan)
40.03A	Tree Pit with Grate in Sidewalk (Section)
40.03B	Tree Pit with Grate in Sidewalk (Section)
40.03C	Tree Pit with Grate in Sidewalk (Section)
40.04A	Drip Irrigation Assembly for Tree Pit with Grate
40.04B	Irrigation Detail (Turf Areas)
40.04C	Irrigation Detail (Planting Beds)
40.04D	Typical Valve Box Installation
40.05	Shrub Planting Bed
40.06	<i>-removed -</i>

40.07	<i>-removed -</i>
40.08A	Median Greater than 120 Inches Excavation, Drainage and Backfill
40.08B	73 to 120 Inch Median Excavation, Drainage and Backfill
40.08C	48 to 72 Inch Median Excavation, Drainage and Backfill
40.09	Root Crown Depths
40.10	Tree Planting Notes
40.11	Bridging Tree Roots
40.12	Temporary Tree Protection Detail
40.13	Asphalt Curb Placement at Existing Trees
40.14	Rock Chimney

5000 Series - Miscellaneous Standards

<u>Standard</u>	<u>Description</u>
50.03	Typical Concrete Control Monument
50.04A	Typical Handrail
50.04B	Handrail Warrants
50.05A	Street Name Sign
50.05B	Street Name Sign (Optional)
50.06	Street Name Sign Installation Locations
50.07A	Dead End Street Barricade
50.07B	Dead End Street Barricade General Notes
50.08A	End of Roadway Marker (ER-1)
50.08B	End of Roadway Marker (ER-2) Guard Rail Clamp Installation
50.09A	Parking Standards
50.09B	Parking Standards (Continued)
50.09C	Parallel Parking Standards
50.10A	Accessible Parking and Signage Standards
50.10B	Supplemental Accessible Sign (R7-8e)
50.10C	Supplemental Accessible Sign (R7-8d)
50.11	Signage and Pavement Markings at Roundabouts
50.12	Emergency Vehicle Median Crossover
50.13	<i>-removed -</i>
50.20	Inverted "U" Rack for Bicycle Parking
50.21	Wave Rack for Bicycle Parking
50.22	Bicycle Lockers

MECKLENBURG COUNTY LAND DEVELOPMENT STANDARDS SPECIFICATIONS AND SPECIAL PROVISION NOTES

The following specifications and special provisions are intended to be used in conjunction with Mecklenburg County Land Development Standard Drawings, NCDOT Roadway Standard Drawings, and NCDOT Standard Specifications for Roads and Structures for all development within the Mecklenburg County and the Town ETJ unless otherwise directed by the Town Engineer.

I. STREETS

A. GENERAL NOTES

1. All work and materials shall conform to the latest edition of the North Carolina Department of Transportation Standard Specifications for Roads and Structures *unless otherwise specified in this manual*.
2. All asphalt cuts shall be made with a saw when preparing street surfaces for patching or widening strips.
3. Paper joints shall be used to seal the ends of an asphalt pour so that future extensions can be made without causing rough joints.
4. When placing asphalt against existing surfaces, a straight edge shall be used to prevent “humping” at that location.
5. Stone shall be primed if paving is not complete within seven days following stone base approval.
6. Surfaces shall be tacked when asphalt is being placed over existing asphalt streets or adjoining concrete, storm drain and sanitary sewer structures.
7. In rolling and hilly terrains, sweeping of the stone base and/or application of a tack coat may be required near intersections. These requirements will be established by the County/NCDOT Inspector based on field conditions.

8. ALL concrete used for streets, curb and gutter, sidewalks and drainage structures, etc. shall have a minimum compressive strength of 3600 PSI at 28 days. This requirement shall be provided regardless of any lesser compressive strength specified in the North Carolina Department of Transportation Standard Specifications for Roads and Structures. The contractor shall prepare concrete test cylinders in accordance with Section 1000 of the North Carolina Department of Transportation Standard Specifications for Roads and Structures at the direction of the project inspector. All equipment and cylinder molds shall be furnished by the contractor. It shall be the responsibility of the contractor to protect the cylinders until such time as they are transported for testing. Testing for projects shall be performed by an independent testing lab, at no cost to the County. The contractor shall provide equipment and perform tests on concrete for a maximum slump and air content as defined in Section 1000 of the North Carolina Department of Transportation Standard Specifications for Roads and Structures. These tests shall be performed at a frequency established by the inspector. Materials failing to meet specifications shall be removed by the contractor.
9. All concrete shall be cured with 100% Resin Base, white pigmented curing compound which meets ASTM Specifications C309, Type 1, applied at a uniform rate at one (1) gallon to 400 square feet within 24 hours of placement of the concrete.
10. All curb and gutter shall be backfilled with soil approved by the Inspector within 48 hours after construction to prevent erosion.
11. All backfill shall be non-plastic in nature, free from roots, vegetative matter, waste, construction material or other objectionable material. Said material shall be capable of being compacted by mechanical means and the material shall have no tendency to flow or behave in a plastic manner under the tamping blows or proof rolling.
12. Materials deemed by the Inspector as unsuitable for backfill purposes shall be removed and replaced with select backfill material.
13. All trenches in the street right-of-way shall be backfilled with suitable material immediately after the pipe is laid. The fill around all pipe shall be placed in layers not to exceed six (6) inches and each layer shall be compacted thoroughly.
14. Under no circumstances shall water be permitted to rise in un-backfilled trenches after the pipe has been placed.

15. Compaction requirements shall be attained by the use of mechanical compaction methods. Each six (6) inch layer of backfill shall be placed loose and thoroughly compacted into place.
16. Straight forms shall not be used for forming curb and gutter in curves.
17. All excess concrete on the front edge (lip) of gutter shall be removed when curb and gutter is poured with a machine.
18. All subgrade shall be compacted to 100% of the maximum density obtainable with the Standard Proctor Test to a depth of eight (8) inches, and a density of 95% Standard Proctor for depths greater than eight (8) inches. All tests shall be performed by developer at no cost to the County.
19. A canvas cover or other suitable cover shall be required for transporting plant mix asphalt during cool weather when the following conditions are present:
 - a. Air temperature is below 60 degrees F.
 - b. Length of haul from plant to job is greater than five (5) miles.
 - c. Other occasions at the Inspector's discretion when a combination of factors indicates that material should be covered in order to assure proper placement temperature.
20. Concrete or asphalt shall not be placed until the air temperature measured at the location of the paving operation is at 35 degrees F and rising by 10:00 a.m. Concrete or paving operations should be suspended when the air temperature is 40 degrees F and descending. The contractor shall protect freshly placed concrete or asphalt in accordance with Sections 420 (Concrete Structures), 600 (Asphalt Bases And Pavements), and 700 (Concrete Pavements And Shoulders) of the North Carolina Department of Transportation Standard Specifications when the air temperature is at or below 35 degrees F and the concrete has not obtained an age of 72 hours. (Exception: asphalt concrete surface course placed on paved surfaces. See the most current NCDOT Superpave Manual for minimum air temperature requirements.)
21. The contractor shall maintain two-way traffic at all times when working within existing streets. The contractor shall place and maintain signs, danger lights, and barricades and furnish watchmen or flagmen to direct traffic in accordance with the latest edition Work Area Traffic Control Handbook (WATCH). Work in the right-of-way of state system streets may require additional traffic control provisions, refer to NCDOT Work Zone Traffic Control Program and/or MUTCD.

22. The contractor shall do that which is necessary to control erosion and to prevent sedimentation damage to all adjacent properties and streams in accordance with the appropriate Mecklenburg County Erosion and Sedimentation Control Ordinance.
23. Roadside ditches shall conform to NCDOT standards unless otherwise specified by Town along Town maintained roads.

B. STANDARDS OF STREET DESIGN

Note: Use of Hilly Terrain criteria is NOT permitted without PRIOR approval of the County Engineer.

Note: Design standards that apply for the ETJ are taken from the January 1, 2000, edition of the NCDOT design manual *Subdivision Roads*. Any revisions to *Subdivision Roads* will supersede the design standards given in the Mecklenburg County Land Development Standards for ETJ streets. However, under no circumstances shall an NCDOT/ETJ standard be less restrictive than what is required by the Mecklenburg County.

1. PUBLIC STREETS:

		<u>Level</u>	<u>Rolling</u>	<u>Hilly</u>
a. Minimum Sight Distance	Local	-----	See AASHTO	-----
	Collector	-----	See AASHTO	-----
b. Maximum Grade (%)	Local	6	10	12
	Collector	4	8	10
c. Minimum Radius (ft)	Local	250	See Town	90
	Collector	350	See Town	175
d. Design Speed	Local	25	25	20
	Collector	30	30	25
e. K Values (Crest/Sag)	Local	28/35	20/20	15/20
	Collector	40/45	28/35	20/20
f. Minimum tangent	Local	50	50	50
between Horizontal curves	Collector	100	100	100
				(NO REVERSE CURVES)

Note: Provisions of adequate stopping sight distance may require use of larger K values than the minimums listed above. Mecklenburg County and/or the town reserves the right to prescribe more stringent sight distance standards and/or means to achieve adequate sight distance than these listed above.

2. INTERSECTIONS:

Criteria is for any proposed street (public or private) that ties into public streets

a. Terrain Classification	<u>Level/Rolling</u> 0-15%	<u>Hilly</u> 15% + (Existing Land Grades)
---------------------------	-------------------------------	--

b. Vertical Alignment is 5% maximum within 100 feet of intersection.

c. Minimum Angle of Intersection is 75 degrees.

d. Min. Curb & R/W Radius (when intersecting streets have different classification, use the more restrictive)

	<u>Level/Rolling</u>	<u>Hilly</u>
Local	25*	25*
Collector	30*	30*

*-See Town for additional requirements

e. Minimum Intersection Separation.

Along local streets 125 feet .

Along collector streets 200 feet

Along thoroughfares to be determined by NCDOT

Intersection offsets/separation from a thoroughfare, at signalized intersections, or at intersections that may become signalized in the future may need to be greater than these minimums and will be determined by NCDOT on a case by case basis.

3. Design criteria for arterial streets shall be established jointly by the County Engineer and the North Carolina Department of Transportation on a case by case basis using the latest edition of the American Association of State Highway and Transportation Officials (AASHTO) A Policy on Geometric Design of Highway and Streets and/or NCDOT Roadway Design Manual.

4. Intersection corner – A minimum 35' x 35' sight triangle easement (measured along right-of-way lines) shall be provided at each intersection corner of roads. An additional 10' x 70' sight triangle easement shall be provided at intersections of roads connecting to NCDOT maintained roadways (measured along right-of-way lines). Driveways (no formal right of way) to serve a single project may be required to provide sight triangle easements as determined on a case by case basis. Other sight distance requirements may be required by NCDOT, the Town or Mecklenburg County at all intersections. Sight lines will be based on NCDOT or AASHTO guidelines.
5. Refer to the NCDOT Subdivision Roads Minimum Construction Manual for development criteria for sites located within the Town's Extraterritorial Jurisdiction (ETJ) within these areas governed by Mecklenburg County Land Development Standards Manual and the NCDOT Subdivision Roads Minimum Construction Standards Manual. The more restrictive standard shall apply.

C. GRADING

1. Proposed street rights-of-way shall be graded to their full width for ditch type streets. Proposed street rights-of-way shall be graded to a minimum of eight (8) feet behind the curb for curb and gutter sections.
2. Fill embankments shall be formed of suitable material placed in successive layers not to exceed more than six (6) inches in depth for the full width of the cross-section, including the width of the slope area. No stumps, trees, brush, rubbish or other unsuitable materials or substances shall be placed in the embankment. Each successive six (6) inch layer shall be thoroughly compacted by the sheepsfoot tamping roller, 10-ton power roller, pneumatic-tired roller, or other methods approved by the County Engineer. Embankments over and around all pipe culverts shall be of select material, placed and thoroughly tamped and compacted as directed by the County Engineer or his representative.

D. ROADWAY BASE

1. All roadways shall be constructed with a base course as described on the appropriate Mecklenburg County Land Development Standard Detail Drawing.
2. The material for stone base course shall conform to the requirements of Section 1010, Aggregate for Non-Asphalt Flexible Type Base, and Section 520, Aggregate Base course of the North Carolina Department of Transportation Standard Specifications for Roads and Structures.
3. The stone base shall be compacted to 100% of the maximum density obtainable with the Modified Proctor Test (AASHTO-T180) by rolling with ring or tamping roller or with a pneumatic tired roller with a minimum weight of ten tons. When completed, the base course shall be smooth, hard, dense, unyielding and well bonded.

4. An asphalt concrete base course, as specified on the Standard Detail Drawing may be substituted in lieu of a stone base course.
5. Asphalt base course will only be allowed within widening strips less than five (5) feet in width.

E. ROADWAY INTERMEDIATE AND SURFACE COURSE

1. All public roadways shall be constructed with an intermediate and surface course as described on the appropriate Mecklenburg County Land Development Standard Detail Drawing.
2. Plant mixed asphalt shall conform in all respects to Section 610 of the North Carolina Department of Transportation Standard Specifications for Roads and Structures.
3. The final (1) one inch lift of asphalt surface course for Residential Subdivision Streets shall be withheld until a minimum of seventy-five percent (75%) of the Development is occupied (occupied means a certificate of occupancy has been issued) or at least (1) one year has lapsed from the application of the intermediate course layer (All documentation to be provided by the developer and approved by the County Inspector). All known base failures shall be repaired prior to application of the final one inch lift of asphalt surface course.
4. The County inspector shall be given a twenty-four (24) hour notification to inspect the intermediate course deficiencies. All deficiency repairs are to be monitored by a County Inspector and accepted prior to application of final layer.
5. County inspectors shall be notified prior to using recycled plant mixes.
6. Failure to meet the above requirements may result in the delay or prevention of street acceptance by the Town or NCDOT.

F. SIDEWALKS AND DRIVEWAYS

1. Sidewalks shall be constructed of not less than 3600 P.S.I. concrete and shall be four (4) inches thick or where a sidewalk crosses a driveway it shall be six (6) inches thick and constructed on an adequately graded base. Subgrade shall be compacted to 95% of the maximum density obtainable with the Standard Proctor Test. The surface of the sidewalk shall be steel trowel and light broom finished and cured with an acceptable curing compound. Tooled joints shall be provided at intervals of not less than five (5) feet and expansion joints at intervals of not more than forty-five (45) feet. The sidewalk shall have a lateral slope of one-quarter (1/4) inch per foot (min).
2. Planting strip adjacent to sidewalk shall be graded to ¼ inch per foot (min.) up to 1 ¼ inch per foot (max.), except where excessive natural grades make this requirement impractical. In such cases, the County Engineer may authorize a suitable grade.

3. Sidewalk widths shall be a minimum of five (5) feet unless otherwise specified.
4. Approval of sidewalk construction plans must be obtained as part of the plan review process. A recorded public sidewalk easement is required for all sidewalk located outside public right-of-way; the width shall be specified by the town. The sidewalk easement must be recorded with the Mecklenburg County Register of Deeds prior to issuance of a certificate of occupancy for the corresponding building(s).
5. Accessible ramps are required where sidewalks intersect curbing at any street intersection and curbed driveway connections.

II. STORM DRAINAGE

A. GENERAL NOTES

1. All work and materials shall conform to the latest edition of the NCDOT Standard Specifications *unless otherwise specified in this manual*. ALL concrete used for drainage structures shall have a minimum compressive strength of 3600 PSI at 28 days. This requirement shall be provided regardless of any lesser compressive strength specified in the North Carolina Department of Transportation Standard Specifications for Roads and Structures.
2. Reinforced concrete pipe may be used in all storm drain applications. High Density Polyethylene Pipe (HDPE) may be substituted for pipe diameters of 48 inches or less as approved by Mecklenburg County and/or the Town. Culverts 60 inches in diameter or greater may be Corrugated Aluminized Metal Pipe (CAMP) or aluminum with a minimum 14 gauge metal, subject to approval of County Engineer.
3. All pipe shall be laid with the bell or groove upgrade and the joint entirely interlocking.
4. The minimum cover for all pipes is two (2) feet measured from the final surface. Special applications for less than two (2) feet of cover will be reviewed and approved by the County Engineer individually. The maximum cover for storm drainage pipes shall at a minimum comply with the requirements of the North Carolina Department of Transportation Highway Design Branch Roadway Design Manual, Part I, Section 5, and “Drainage Design”. Storm pipe design that exceeds these criteria may be approved at the discretion of the County Engineer.
5. All pipes in storm drain structures shall be flush with the inside wall.
6. All storm drain structures over three (3) feet and six (6) inches in height must have steps in accordance with standard details set forth in this manual.

7. The interior surfaces of all storm drainage structures shall be pointed up and smoothed to an acceptable standard using mortar mixed to manufacturer's specifications.
8. All frames, grates, rings, covers, etc., must conform to the standards set forth in this manual.
9. All graded creek banks and slopes shall be at a maximum of two (2) feet horizontal to one (1) foot vertical (2:1) and not to exceed 10' without terracing or the slopes shall be designed by a Professional Geotechnical Engineer and approved by the County Engineer on a case by case basis.

B. HIGH DENSITY POLYETHYLENE PIPE (HDPE)

1. Any installation within the maintenance limits of the town is subject to the approval of the town engineer/public works director.
2. The Product used shall be corrugated exterior/smooth interior pipe (Type S), conforming to the requirements of AASHTO Specification M294 (latest edition) for Corrugated Polyethylene Pipe.
3. Bell and spigot joints shall be required on all pipes inside the right-of-way. Bells shall cover at least two full corrugations on each section of pipe. The bell and spigot joint shall have an "O" ring rubber gasket meeting ASTM F477 with the gasket factory installed, placed on the spigot end of the pipe. Pipe joints shall meet all requirements of AASHTO M294.
4. All HDPE pipe installed must be inspected and approved by the County's Inspector prior to any backfill being placed. The County inspector must be present during the backfilling operation as well.
5. Backfill material used to install HDPE pipe within the street right-of-way shall be Select Material, Class II-IV, as defined by Section 1016-3 of the North Carolina Department of Transportation Standard Specifications for Roads and Structures. Upon submittal of written certification of material suitability by a licensed geotechnical engineer, NCDOT Class I Select Material may be used. All backfill material shall be approved by the County inspector prior to placement of the material within the town street right-of-way.
6. The minimum length of HDPE pipe permitted for use shall be four (4) feet. HDPE flared end sections are not allowed.
7. All HDPE pipe installed shall be third party certified and shall bear the Plastic Pipe Institute's (PPI) certificate sticker.

C. REINFORCED CONCRETE.

1. All concrete shall be at least 3600 PSI. Prior approval shall be obtained in order to use pre-cast storm drainage structures in any street right-of-way by County Engineer.
2. Concrete pipe used within the street right-of-way shall be a minimum of Class III Reinforced Concrete Pipe, with a minimum diameter of fifteen (15) inches (eighteen (18) inches minimum on cross drain culverts). Installation of Class IV or higher concrete pipe shall be identified on the As-Built Plan and the County inspector shall be given documentation and notification of this information prior to construction.
3. Concrete mortar joints shall be used for joining all concrete pipes. The pipe shall be clean and moist when mortar is applied. The lower portions of the bell or groove shall be filled with mortar sufficient to bring the inner surface flush and even when the next joint is fitted into place. The remainder of the joint shall then be filled with mortar and a bead or ring of mortar formed around the outside of the joint. The application of mortar may be delayed until fill is completed when the pipe is larger than thirty (30) inches.
4. Performed joint sealer, which conforms to AASHTO specification M-198 for Type B flexible plastic gaskets, may be used in lieu of the mortar joining method.

D. INSTALLATION OF REINFORCED CONCRETE AND CORRUGATED METAL PIPE.

1. All backfill shall be non-plastic in nature, free from roots, vegetative matter, waste, construction material or other objectionable material. Said material shall be capable of being compacted by mechanical means and shall have no tendency to flow or behave in a plastic manner under the tamping blows or proof rolling.
2. Materials deemed by the Engineer as unsuitable for backfill purposes shall be removed and replaced with select backfill material.
3. Backfilling of trenches shall be accomplished immediately after the pipe is laid. The fill around the pipe shall be placed in layers not to exceed eight (8) inches, each layer shall be thoroughly compacted to 95% of the maximum density obtainable with the Standard Proctor Test (a density of 100% Standard Proctor is required for the top eight (8) inches).
4. Compaction requirements shall be attained by the use of mechanical compaction methods. Each layer of backfill shall be placed loose and thoroughly compacted in place.
5. Under no circumstances shall water be permitted to rise in un-backfilled trenches after the pipe has been placed.

E. STANDARDS FOR DESIGN

1. All storm drainage design shall conform to the standards and specifications as provided in the Charlotte-Mecklenburg Storm Water Design Manual, North Carolina Department of Transportation Standards Specifications for Roads and Structures, Mecklenburg County Land Development Standards Manual, or the more restrictive of any standards that conflict.
2. Adequate storm drainage shall be provided throughout the development by means of storm drainage pipes or properly graded channels. All pipes shall be of adequate size and capacity, as approved by the County Engineer, to carry all storm water in its drainage area.
3. In accordance with County Zoning Ordinance, the County Engineer shall review the drainage plan for compliance with the standards contained in the current edition of the Mecklenburg County Land Development Standards Manual and the Charlotte-Mecklenburg Storm Water Design Manual and all other relevant and appropriate standards established by the County Engineering Department.
4. Sub-surface drainage shall be provided where the ground water level is likely to be near the surface. In capillary soils, the water level should be four (4) to six (6) feet below the surface to prevent the rise of moisture into the subgrade. Four (4) inch PVC or HDPE pipe with open joints or perforations shall be used to lower ground water in low areas in the street.
5. The NCDOT Standard Drawings have been accepted as approved standards to be specified for land development projects in the County. See standard #20.00 A, B and C of this manual for a table listing the standards accepted. These standard drawings shall be referenced by NCDOT number or shown on all plans submitted to the County for approval.

III. PLAN REQUIREMENTS

A. GENERAL NOTES

1. All erosion control measures shall conform to the standards set forth in the Mecklenburg County Land Development Standards Manual, North Carolina Erosion and Sediment Control Planning and Design Manual, or the more restrictive of any standards that conflict.
2. All storm drainage design shall conform to the standards and specifications as provided in the Charlotte-Mecklenburg Storm Water Design Manual, Mecklenburg County Land Development Standards Manual, or the more restrictive of any standards that conflict.
3. In areas where the Floodway Regulations are applicable, the Future Conditions Flood Fringe Line, FEMA Flood Fringe Line, Community Encroachment Line, and FEMA Encroachment Line shall be shown on the concept plan, preliminary plan and the final plat. An application for a Floodlands Development Permit shall be submitted to Mecklenburg County Engineering in accordance with the requirements set forth in the City/County Floodway Regulations.

4. Cite all appropriate standard detail numbers for any structures or specifics used within the plans in reference to the most current copy of the Mecklenburg County Land Development Standards Manual.

B. SUBDIVISION PRELIMINARY PLAN

1. The preliminary plan must include, at a minimum, the information described in each Town's Subdivision Ordinance or other applicable ordinance.
2. Storm Drainage Easements shall be provided for all storm drainage pipes and shown on site plans, construction plans and plats with widths as specified by detail #20.30. The following note shall be placed on all grading plans and plats; "The purpose of the storm drainage easement (SDE) is to provide storm water conveyance. Buildings are not permitted in the easement area. Any other objects which impede storm water flow or system maintenance are also prohibited."
3. A Storm Drainage Easements must extend down stream of flared end sections to an appropriate property line or buffer. Overlapping of storm drainage easements shall be approved by the County Engineer.

C. BOND POLICY – SUBDIVISION IMPROVEMENTS.

1. Release of the final subdivision plat will not occur until the improvements required for the area of the final plat are constructed and a final inspection has been performed and found to be in conformance with the plans approved by the Town and Mecklenburg County, or a security has been posted with the Land Development Bond Coordinator of the applicable department and all required documents are received in their entirety.
2. Securities shall be posted for a minimum of six months with a two year maximum. The security shall remain in force until the construction is complete and found to be in conformance with plans approved by the Town and Mecklenburg County. The security will be reevaluated when an extension to the security is being considered.
3. A final inspection will be made by the county engineer to check completeness of the project upon receipt of a notice.
4. One type of security may be replaced by another type of security in certain situations. The amount of the replacement security will be based on the County's estimate of the work remaining. If the estimate of work results in a lower amount, the replacement security will be treated as a reduction. Certain situations will require an increase in a security and in such cases the replacement security shall be required to equal the higher amount.

5. If Mecklenburg County and the Town have different security requirements, the more restrictive shall apply.
6. A one-time reduction in security will be allowed if requested in writing by the principal party of the security. Additional reductions may be approved at the discretion of the County Engineer. However, the security shall never be less than 15% of the total bond or \$20,000 for the County unless approved by the County Engineer.
7. Securities in the form of a Letter of Credit must be drawn on a full service bank in Mecklenburg County.
8. The applicant will be required to post a maintenance bond per Town requirements before the security for completion of subdivision is released.

REFERENCES

1. North Carolina Department of Transportation, most recent edition, Standard Specifications for Roads and Structures.
2. North Carolina Department of Transportation, most recent edition, Roadway Standards Drawings.
3. City of Charlotte Department of Transportation, most recent edition, Work Area Traffic Control Handbook (WATCH)
4. City of Charlotte Storm Water Services-Mecklenburg County Storm Water Services most recent edition, Charlotte-Mecklenburg Storm Water Design Manual
5. American Association of State Highway and Transportation Officials most recent edition, A Policy on Geometric Design of Highways and Streets
6. North Carolina Department of Transportation, Roadway Design Manual, latest edition
7. North Carolina Department of Environment and Natural Resources most recent edition, Erosion and Sediment Control Planning and Design Manual
8. Charlotte-Mecklenburg BMP Design Manual, latest edition.
9. Mecklenburg County Storm Water Services, most recent edition, Administrative Manual for Implementation of the Post-Construction Storm Water Ordinance
10. Mecklenburg County Board of County Commissioners, most recent edition, Mecklenburg County Soil and Sedimentation Control Ordinance
11. Manual of Uniform Traffic Control Devices for Streets and Highways, Federal Highway Administration, latest edition.

MCLDS Revision Log

Revisions Effective July 1, 2010

Standard No.	Name	Description of Revision
11.09	Arterial Street Typical Sections	Corrected the pavement end treatment.
11.18A	Residential Hammerhead Detail	Corrected standard number.
11.18B	Temporary Turnaround Local Residential Street	Corrected standard number.
11.50	Cornelius, Davidson, and Huntersville Typical Section Residential Street	Huntersville notes changed to refer to Huntersville Engineering Standards.
11.56	Cornelius, Davidson, and Huntersville Typical Section Cul-de-Sac Detail	Added reference to Huntersville standards.
20.28	Subdrain Detail	Added notes 6 and 7.
21.00	Bioretention Plan	Revised sod label. Revised cleanout label.
21.01	Bioretention Cross-Section	Revised standard per BMP Manual revision.
21.03	Bioretention Concrete Curb Spillway	Removed.
21.06	Wetpond Profile	Corrected location of water quality orifice.
21.08	Wetpond Littoral Shelf and Berm Detail	Corrected location of water quality orifice.
21.09	Wetpond Planting Plan	Corrected location of water quality orifice.
21.23	Underground Sand Filter	Added underdrain pipe size. Added cleanout label with spacing requirement.
21.24	Surface Sand Filter	Revised note 3 per BMP Manual revision.
21.25	Surface Sand Filter Section	Added note 3. Added sand thickness. Added filter fabric under gravel.
30.01	Temporary Sediment Trap	Changed shading in cross-section. Added note 2.
30.02A	Skimmer Sediment Basin	Corrected data block. Added emergency spillway width. Corrected the freeboard dimension location.
30.03	Sediment Basin	Added note 4. Corrected data block. Corrected emergency spillway invert elevation and dimension location per NCESCPDM 6.60. Corrected freeboard dimension location per NCESCPDM 6.60. Added minimum H.
30.04	Flexible Pipe Slope Drain	Added stake. Corrected labels.
30.05	Temporary Silt Ditch	Added dimensions.
30.06D	Silt Fence Outlet Option 2	Removed note 2. Corrected labels and cross-section.
30.07	Block and Gravel Inlet Protection	Added min. & max. height. Added slope. Removed Stone from standard name.
30.08	Stone Inlet Protection	Revised per NCESCPDM 6.54. Added note 7.

30.10A	Temporary Rock Check Dam	Removed note 1. Added filter cloth to cross-section. Added thickness of #5 stone layer.
30.10B	Temporary Rock Check Dam With Matting and Optional PAM	New detail.
30.10C	Temporary Wattle Check Dam With Matting and Optional PAM	New detail.
30.11A	Stabilized Construction Entrance	Corrected stone size per NCESCPDM 6.06.
30.11B	Construction Entrance Tire Wash	Corrected stone size per NCESCPDM 6.06.
30.12	Gravel and Rip Rap Filter Berm Basin	Corrected standard per NCESCPDM 6.55. Added note 2.
30.14	Temporary Stream Crossing	Revised per NCESCPDM 6.70.
30.16	Slope Stability	Moved silt fence outside of 10' construction access.
30.18	Construction Within Creek Bank	Corrected spelling of construction in note 5.
50.05A	Street Name Sign	Revised Note 4 per 2009 MUTCD.
50.05B	Street Name Sign (Optional)	Revised Note 2 per 2009 MUTCD.